

Routing Slip

From

FILE

to: City Departments

ATTENTION OF:

- ☐ Airport
- ☐ Art Museum
- ☐ Building Regulations
- ☐ City Attorney
- ☐ Prosecutor
- ☐ City Clerk
- ☐ Mayor/City Council
- ☐ City Manager
- ☐ Public Information
- ☐ Risk Manager
- ☐ Word Processing
- ☐ Communications (911)
- ☐ Fire
- ☐ Finance
 - ☐ Accounting
 - ☐ Budget & Evaluation
 - ☐ Licensing
 - ☐ Printshop
 - ☐ Purchasing
- ☐ Health
 - ☐ Air Pollution
 - ☐ Clinic
- ☐ Human Resources
- ☐ Human Rights
- ☐ Municipal Court
- ☐ Parks
- ☐ Personnel
- ☐ Planning & Development

- ☐ Police Department
- ☐ Public Works
 - ☐ Engineering
 - ☐ General Services
 - ☒ Sanitary Services
 - ☐ Solid Waste/Materials
 - ☐ Recovery
 - ☐ Street Maintenance
 - ☐ Traffic

Other Offices

- ☐ Chamber of Commerce
- ☐ City Utilities
- ☐ Emergency Mgmt.
- ☐ Greene County
- ☐ Library
- ☐ Pace
- ☐ Watershed Management

MESSAGE:

Bob,
FLASHPOINT must be
140°F. AND limits
meet local R. -
is acceptable for us to
take their word.

Candy
Look at this
see if it
to Bob

ATTENTION OF :

DATE: 5-25-94

FM: Steve Strader, Assistant Chief *MS*
TO: Steve Short, Wastewater Quality Officer
RE: Fire Training Burn Pit



Steve, I wanted to thank you for your efforts on our behalf to gain approval of the burn pit at 4800 N. Farmer. I would like to clarify the remaining improvements needed to gain DNR approval.

1. The overflow drain needs to be sealed up to create a self contained holding area.
2. The residual water mixture needs to be periodically pumped into the sanitary sewer system to prevent runoff from the overflow. We also intend to treat the residue with Bio-solve or a similar material after each usage.
3. The only material used for fuel will be virgin fuel.

I would like to obtain written approval from DNR prior to using the facility. Please steer me on the right course to this end.

Many thanks

cc:
Dan Weber
Ron Boyer
Bob Schaefer
Tom Holst

*BOB C.
Please Comment
Should test before
discharge to POTW
Needs to meet local
levels O&G, flashpoint
etc BCF, 6-1-94*

*Called Steve Strader 6/13/94 10:05 A.M.
told him to call us when ready to discharge
and we would sample for O&G + Local
limits ^{+ FLASHPOINT} before they discharge. R.*

4800 N. Farmer